



Paul PCS - Lead in Water Test Results



FY25 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

Charter Campus Name	Water Source ID	Device Type	Floor	Device Location	Location Identifier		Water Filter ID	Date Analyzed	Draw A Sample ID	FT Final Results - Draw A (ppb)	Draw B Sample ID	FT Final Results - Draw B (ppb)
					High/Low	Left/Mid/Right						
Paul PCS	WS-032-001	Cooler	3	In hallway adjacent to stairway 8 on north side			WF-012025-032001-07		FT-FY25-012025-032001-A		FT-FY25-012025-032001-B	
Paul PCS	WS-032-002	Cooler	3	In hallway adjacent to room 305			WF-012025-032002-07	5/23/2025	FT-FY25-012025-032002-A	<1	FT-FY25-012025-032002-B	<1
Paul PCS	WS-032-003	Cooler	3	In hallway adjacent to room 309			WF-012025-032003-08	5/23/2025	FT-FY25-012025-032003-A	<1	FT-FY25-012025-032003-B	<1
Paul PCS	WS-032-004	Break Room	3	In break room S302			WF-012025-032004-09	5/23/2025	FT-FY25-012025-032004-A	<1	FT-FY25-012025-032004-B	<1
Paul PCS	WS-032-005	Cooler	2	In hallway adjacent to room S204			WF-012025-032005-07	5/23/2025	FT-FY25-012025-032005-A	<1	FT-FY25-012025-032005-B	<1
Paul PCS	WS-032-006	Cooler	2	In hallway adjacent to room 210			WF-012025-032006-08	5/23/2025	FT-FY25-012025-032006-A	<1	FT-FY25-012025-032006-B	<1
Paul PCS	WS-032-007	Cooler	2	In hallway adjacent to room 206			WF-012025-032007-07	5/23/2025	FT-FY25-012025-032007-A	<1	FT-FY25-012025-032007-B	<1
Paul PCS	WS-032-008	Cooler	2	In hallway adjacent to room N201			WF-012025-032008-07	N/A	FT-FY25-012025-032008-A	Non-operational	FT-FY25-012025-032008-B	Non-operational
Paul PCS	WS-032-009	Cooler	1	In hallway adjacent to room N104			WF-012025-032009-07	5/23/2025	FT-FY25-012025-032009-A	<1	FT-FY25-012025-032009-B	<1
Paul PCS	WS-032-010	Break Room	1	In staff lounge N107			WF-012025-032010-07	5/23/2025	FT-FY25-012025-032010-A	<1	FT-FY25-012025-032010-B	<1
Paul PCS	WS-032-011	Cooler	1	In hallway adjacent to room 105			WF-012025-032011-07	5/23/2025	FT-FY25-012025-032011-A	<1	FT-FY25-012025-032011-B	<1
Paul PCS	WS-032-012	Cooler	1	In hallway adjacent to room 108			WF-012025-032012-07	5/23/2025	FT-FY25-012025-032012-A	<1	FT-FY25-012025-032012-B	<1
Paul PCS	WS-032-014	Cooler	Basement	In cafeteria north side			WF-012025-032014-07	5/23/2025	FT-FY25-012025-032014-A	<1	FT-FY25-012025-032014-B	<1
Paul PCS	WS-032-015	Food Prep Sink	Basement	In kitchen 1st sink clockwise from door		Left	WF-012025-032015-07	5/23/2025	FT-FY25-012025-032015-A	<1	FT-FY25-012025-032015-B	<1
Paul PCS	WS-032-016	Food Prep Sink	Basement	In kitchen 2nd sink clockwise from door		Right	WF-012025-032016-07	5/23/2025	FT-FY25-012025-032016-A	<1	FT-FY25-012025-032016-B	<1
Paul PCS	WS-032-017	Cooler	Basement	In cafeteria south side			WF-012025-032017-07	5/23/2025	FT-FY25-012025-032017-A	<1	FT-FY25-012025-032017-B	<1
Paul PCS	WS-032-018	Cooler	2	In hallway across from room 208 in new building	High	Left	WF-012025-032018-07	N/A	FT-FY25-012025-032018-A	Non-operational	FT-FY25-012025-032018-B	Non-operational
Paul PCS	WS-032-019	Cooler	2	In hallway across from room 208 in new building	Low	Right	WF-012025-032019-07	N/A	FT-FY25-012025-032019-A	Non-operational	FT-FY25-012025-032019-B	Non-operational
Paul PCS	WS-032-020	Cooler	1	In hallway across from room 109 in new building	High	Left	WF-012025-032020-07	N/A	FT-FY25-012025-032020-A	Non-operational	FT-FY25-012025-032020-B	Non-operational
Paul PCS	WS-032-021	Cooler	1	In hallway across from room 109 in new building	Low	Right	WF-012025-032021-07	N/A	FT-FY25-012025-032021-A	Non-operational	FT-FY25-012025-032021-B	Non-operational
Paul PCS	WS-032-022	Ice Maker	Basement	In kitchen			WF-012025-032022-07	5/23/2025	FT-FY25-012025-032022-A	<1	FT-FY25-012025-032022-B	<1
Paul PCS	WS-032-023	Bottle Filler	1	In hallway adjacent to room 108	High		WF-012025-032023-07	5/23/2025	FT-FY25-012025-032023-A	<1	FT-FY25-012025-032023-B	<1
Paul PCS	WS-032-026	Bottle Filler	3	In hallway adjacent to room 305			WF-012025-032026-05	5/23/2025	FT-FY25-012025-032026-A	<1	FT-FY25-012025-032026-B	<1
Paul PCS	WS-032-027	Bottle Filler	3	In hallway adjacent to room 309			WF-012025-032027-06	5/23/2025	FT-FY25-012025-032027-A	<1	FT-FY25-012025-032027-B	<1
Paul PCS	WS-032-028	Bottle Filler	2	In hallway adjacent to room S204			WF-012025-032028-05	5/23/2025	FT-FY25-012025-032028-A	<1	FT-FY25-012025-032028-B	<1
Paul PCS	WS-032-029	Bottle Filler	2	In hallway adjacent to room 210			WF-012025-032029-06	5/23/2025	FT-FY25-012025-032029-A	<1	FT-FY25-012025-032029-B	<1
Paul PCS	WS-032-030	Bottle Filler	2	In hallway adjacent to room 206			WF-012025-032030-05	5/23/2025	FT-FY25-012025-032030-A	<1	FT-FY25-012025-032030-B	<1
Paul PCS	WS-032-031	Bottle Filler	2	In hallway adjacent to room N201			WF-012025-032031-05	N/A	FT-FY25-012025-032031-A	Non-operational	FT-FY25-012025-032031-B	Non-operational
Paul PCS	WS-032-032	Bottle Filler	1	In hallway adjacent to room N104			WF-012025-032032-05	5/23/2025	FT-FY25-012025-032032-A	<1	FT-FY25-012025-032032-B	<1
Paul PCS	WS-032-033	Bottle Filler	1	In hallway adjacent to room 105			WF-012025-032033-05	5/23/2025	FT-FY25-012025-032033-A	<1	FT-FY25-012025-032033-B	<1
Paul PCS	WS-032-034	Bottle Filler	Basement	In cafeteria north side			WF-012025-032034-05	5/23/2025	FT-FY25-012025-032034-A	<1	FT-FY25-012025-032034-B	<1
Paul PCS	WS-032-035	Bottle Filler	Basement	In cafeteria south side			WF-012025-032035-05	5/23/2025	FT-FY25-012025-032035-A	<1	FT-FY25-012025-032035-B	<1